

Number	25-004684-PR04 (NW-A01-0203-en-01)
Owner	ASAS Alüminyum San.ve Tic.A.S. Rüzgarlı Bahçe Mah., Kumlu Sok. No.2 Asas Is Merkezi, 34810 Kavacik-Beykoz ISTANBUL Türkiye
Product	Tilt and turn window with fixed sidelight
Designation	System: ASW34 Product designation: ASW34 Window
Details	Manufacturer ASAS Alüminyum San.ve Tic.A.S. - Kavacik-Beykoz ISTANBUL; Material Aluminium system with thermal break; Type of opening Tilt and turn; Opening direction DIN left, inward opening; Overall dimensions (W x H) 1200 mm x 1200 mm
Special features	Test sequence. Position of locking. Material compatibility must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of this test and must be tested separately if necessary.

Results **)

Operating forces according to EN 13115:2020-08



Class: 1

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C5/B5

Watertightness according to EN 12208:1999-11



Class: E750

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim

03.07.2026



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Alexandros Simeonidis, B.Eng.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions
(e.g. DIN EN)

Test report 25-004684-PR04 PB-
A01-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift-Test Documents" applies.

Identity-Check



www.ift-tested.de
ID: 128-DF36D